

American Standard

Programmable Thermostat

ASYSTAT 340

OWNER'S GUIDE



Pub. No. 12-5026-01




69-1609

FEATURES

American Standard sells comfort systems. Comfort is achieved through matching the correct equipment and controls. This thermostat is designed to provide the maximum comfort for your needs. Some of the basic offerings are:

- Program up to four time periods and temperature settings to complement your lifestyle.
- Set different schedules for weekdays and weekends.
- Programs are permanently held in memory in the event of a power failure.
- Indefinite temperature hold.
- Preprogrammed for your convenience.



Your thermostat displays the current day, time, period, temperature and system (🔥 for heating and ❄️ for cooling) in normal mode. In programming mode, only the setting or settings being programmed display. For example "SAT SUN" (Saturday Sunday) displays while programming the weekend schedule.

SET DISPLAYS WHILE SETTING THE CLOCK.

CURRENT TIME DISPLAYS IN NORMAL MODE.
PERIOD START TIME DISPLAYS IN PROGRAMMING MODE.

CURRENT DAY DISPLAYS IN NORMAL MODE. **MONDAY THROUGH FRIDAY** DISPLAY DURING WEEKDAY PROGRAMMING MODE.
SATURDAY AND SUNDAY DISPLAY DURING WEEKEND PROGRAMMING MODE.

DURING NORMAL MODE, THE CURRENT PERIOD DISPLAYS. DURING PROGRAMMING, THE PERIOD BEING PROGRAMMED DISPLAYS (**WAKE, LEAVE, RETURN OR SLEEP**).

FLAME DISPLAYS DURING HEATING OR WHILE PROGRAMMING HEATING SETPOINT; **SNOWFLAKE** DISPLAYS DURING COOLING OR WHILE PROGRAMMING COOLING SETPOINT.

CURRENT TEMPERATURE DISPLAYS. HEATING OR COOLING SETPOINT DISPLAYS DURING PROGRAMMING.

TEMPORARY DISPLAYS DURING TEMPORARY TEMPERATURE HOLD.



M18560

PROGRAMMING YOUR THERMOSTAT

CLOCK

Setting the Current Day and Time

To set or reset the current day and time, follow these instructions:

IMPORTANT

Always press the keys with your fingertip or similar blunt tool. Sharp objects like pen and pencil points will damage the keyboard.

Note: To exit and save the time and day setting at any time, press **Hold**.

1. To set Current Time, press **Select** twice. Press ▲ or ▼ to set current time.



M12591A

Note: While setting the current time, SET displays.

2. To set Day of Week, press **Select** again. Press ▲ or ▼ to set current day.



M18565

3. Press **Hold** to exit the day and time mode.

Organizing Your Schedule

Your thermostat can be set for four time periods (Wake, Leave, Return, and Sleep) for the weekday schedule (Monday through Friday), and four time periods for the weekend schedule (Saturday and Sunday). Without additional programming, your thermostat follows the same preprogrammed schedule for both weekdays and weekends (see Table 1).

- WAKE** Choose the time you want your heating or cooling system to start to reach your comfort temperature after the SLEEP period.
- How? Consider the time required to reach your comfort level. Adjust the Wake time to earlier when you know it will take the system longer to reach your comfort temperature.
- LEAVE** Choose the time you want your heating or cooling system to start an energy-saving mode while you are away at work or school.
- How? Set the Leave temperature lower during heating season, and higher during cooling season.

- RETURN** Choose the time you want your heating or cooling system to start to reach your comfort temperature after the energy-savings LEAVE period.
- How? Consider the time required to reach your comfort level. Adjust the Return time to earlier when you know it will take the system longer to reach your comfort temperature.
- SLEEP** Set the time you want your heating or cooling system to start to reach your Sleep temperature.
- To use this period as an energy-savings mode, set the temperature lower during heating season, and higher during cooling season.

The preprogrammed schedule is shown in Table 1. You may keep this schedule or organize your own. Schedules are adjustable as often as you wish. If you decide to keep this schedule, no further programming is necessary.

Table 1. Preprogrammed Weekday and Weekend Schedule.

Period	Time	Heat Setpoint	Cool Setpoint
Wake	6:00 AM	70°F (21 °C)	78°F (26 °C)
Leave	8:00 AM	62°F (17 °C)	85°F (29 °C)
Return	5:00 PM	70°F (21 °C)	78°F (26 °C)
Sleep	10:00 PM	62°F (17 °C)	75°F (24 °C)

To begin programming your weekday and weekend schedules, fill in Tables 2 and 3.

Customizing Your Weekday Schedule

Use Table 2 to organize your weekday schedule. Fill in the times and temperatures you want to program. The names of the four periods are filled in for you.

Table 2. Your Weekday Schedule.

Period	Start Time	Heating Temperature	Cooling Temperature
Wake			
Leave			
Return			
Sleep			

Customizing Your Weekend Schedule

Use Table 3 to organize your weekend schedule. Fill in the times and temperatures you want to program. The names of the four periods are filled in for you.

Table 3. Your Weekend Schedule.

Period	Start Time	Heating Temperature	Cooling Temperature
Wake			
Leave			
Return			
Sleep			

Note: Start Time is the time your thermostat begins to reach the desired temperature.

Note: The thermostat cannot be set higher than 99°F (37°C) or lower than 50°F (10°C).


Setting the Weekday Program

IMPORTANT

Always press the keys with your fingertip or similar blunt tool. Sharp objects like pen and pencil points will damage the keyboard.

1. Slide the SYSTEM switch to the setting you want to program (Heat or Cool).


Throughout programming, the thermostat displays a flame 🔥 (heating) or snowflake ❄️ (cooling) to help you identify which mode you are programming. At the end of Setting the Weekend Program, you are prompted to return to this step to program the opposite mode. Example shows Cool setting.



Note: To exit the programming mode at any time, press **Hold** (the thermostat saves your changes).

2. Set weekday Wake time and temperature.

- a. Press **Select** four times. Press ▲ or ▼ to set Wake time.



M18570

Note: Schedule times are programmable in increments of 15 minutes. For each press, the time increases or decreases by 15 minutes.

- b. Press **Select**. Press ▲ or ▼ to set Wake temperature.



M18564

Note: When setting the Weekday Program, the days *MON TUE WED THU FRI* display.

3. Set weekday Leave time and temperature.

- a. Press **Select**. Press ▲ or ▼ to set Leave time.



M18566

- b. Press **Select**. Press ▲ or ▼ to set Leave temperature.



M18561

- b. Press **Select**. Press ▲ or ▼ to set Return temperature.



M18562

4. Set weekday Return time and temperature.

- a. Press **Select**. Press ▲ or ▼ to set Return time.



M18567

5. Set weekday Sleep time and temperature.

- a. Press **Select**. Press ▲ or ▼ to set Sleep time.



M18568

- b. Press **Select**. Press ▲ or ▼ to set Sleep temperature.



M18563


IMPORTANT:

*Before pressing another key,
continue with Setting the Weekend
Program.*

Setting the Weekend Program

Note: For initial programming, you must set the weekday schedule as shown in Setting the Weekday Program before you can access weekend programming. If your weekday is already programmed, you can access weekend programming by pressing **Select** 12 times.

1. Set weekend Wake time and temperature.
 - a. Press **Select**. Press ▲ or ▼ to set Wake time.



M18569

Pub. No. 12-5026-01
69-1609

Example shows Cool setting.

- b. Press **Select**. Press ▲ or ▼ to set Wake temperature.




M18549

Note: When setting the Weekend Program, the days *SAT SUN* display.

2. Set weekend Leave time and temperature.

- a. Press **Select**. Press ▲ or ▼ to set Leave time.



M18550


- b. Press **Select**. Press ▲ or ▼ to set Leave temperature.



M18551

3. Set weekend Return time and temperature.

- a. Press **Select**. Press ▲ or ▼ to set Return time.



M18552


- b. Press **Select**. Press ▲ or ▼ to set Return temperature.



M18553

4. Set weekend Sleep time and temperature.

- a. Press **Select**. Press ▲ or ▼ to set Sleep time.



M18554

- b. Press **Select**. Press ▲ or ▼ to set Sleep temperature.




M18555

5. Press **Select**. End displays.



M18556

After five seconds, your thermostat displays the current day, time and temperature.



M18557

6. Return to **Step 1., Setting the Week-day Program** to program the opposite mode, 🔥 (heating) or ❄️ (cooling).

Your weekday and weekend schedules are now programmed.

Temporary Temperature Hold

1. Press ▲ or ▼ key twice to set a temporary temperature.




M18558

Note: The temporary temperature setting remains in effect until the next program period. To cancel, press **Hold** twice and wait five seconds.

Indefinite Temperature Hold

The **Hold** key allows you to hold a temperature indefinitely. When Hold is active, *Hld* displays continuously.

1. Press **Hold**.
2. Press ▲ or ▼ key to set indefinite temperature setting.



M18559

3. To cancel, press **Hold** and wait five seconds.

System and Fan

Use the SYSTEM and FAN switches to change the settings.

System Setting


To select the desired system setting, slide the SYSTEM switch in the lower right corner of the thermostat.

SYSTEM settings control the thermostat operation as follows:

Cool: The thermostat controls the cooling.

Off: Both the heating and cooling are off.

Heat: The thermostat controls the heating.



Heat and Cool Indicators

🔥 Indicates a call for heating.

❄️ Indicates a call for cooling.




M18548

Note: In the programming mode, the 🔥 and ❄️ indicate the system setting.

Fan Setting

To select the desired fan setting, slide the FAN switch in the lower left corner of the thermostat.



FAN settings control the system fan as follows:
Auto: Fan operates with equipment.
On: Fan operates continuously.

Minimum Off-Timing

Your thermostat comes equipped with a minimum off-timer. At certain times during cooling, the system will not start up again for at least five minutes after it turns off (compressor is off and can't be heard). This occurs when you change the SYSTEM switch position while the compressor is off or when you change the temperature setting, causing the compressor to turn off. The minimum off-timer is also triggered during power interruption and power restoration. You will know the minimum off time is in effect by a flashing 🔥 or ❄️ on the display.



CAUTION

Equipment Damage Hazard.
Can cause permanent damage to the compressor or other equipment.
To avoid possible equipment damage, do not operate cooling when outside temperature is below 50°F (10°C). See equipment manufacturer instructions. To avoid possible compressor damage, allow the compressor to remain off for five minutes before restarting.

TROUBLESHOOTING GUIDE





Symptom	Possible Cause	Action
Display will not come on.	Thermostat is not being powered.	Check if the thermostat is mounted and latched on the wallplate—mount and latch the thermostat on the wallplate. Check if the circuit breaker is tripped—reset the circuit breaker. Check if the fuse is blown—replace the fuse. Check if the system switch is in the Off position—set to Heat or Cool.
Temperature settings will not change (Example: cannot set the heating higher or the cooling lower).	The upper or lower temperature limits were reached.	Check that the temperature setpoints are within range: Heating: 50° to 99° F (10° to 37° C) Cooling: 50° to 99° F (10° to 37° C).

(Continued)

Troubleshooting (Continued)

Symptom	Possible Cause	Action
Heating will not come on.	No power to the thermostat. System selection is not set to Heat. Heating setpoint is below room temperature.	Check that the setpoint is above room temperature—reset temperature or wait for room temperature to fall. Check if the circuit breaker is tripped—reset the circuit breaker. Check if the fuse is blown—replace the fuse. Check if the system switch at the equipment is in the Off position—set to Heat position. Wait five minutes for the system to respond.
Cooling will not come on.	No power to the thermostat. System selection is not set to Cool. Cooling setpoint is above room temperature.	Check that the setpoint is below room temperature—reset temperature or wait for room temperature to rise. Check if the circuit breaker is tripped—reset the circuit breaker. Check if the fuse is blown—replace the fuse. Check if the system switch at the equipment is in the Off position—set to Cool position. Wait five minutes for the system to respond.

Troubleshooting (Continued)

Symptom	Possible Cause	Action
System on indicator  and  is lit, but no warm or cool air is coming from the registers.	Heating/cooling equipment turns on the fan when the equipment has reached the setpoint.	Wait a minute after seeing the flame or snowflake and then check the registers.
System on indicator  or  is flashing	Minimum off timer is in effect.	Wait five minutes until the minimum off timer is complete.

LIMITED WARRANTY

Low Voltage Room Thermostats

This warranty is extended by American Standard Inc., to the original purchaser and to any succeeding owner of the real property to which the **Thermostat** is originally affixed, and applies to products purchased and retained for use within the U.S.A. and Canada.

If any part of your **Thermostat** fails because of a manufacturing defect within five years from the date of the original purchase, Warrantor will furnish without charge a new thermostat. **Any local transportation, related service labor and diagnosis calls are not included.**

This limited warranty applies to product installed on or after 10/1/2001 where product is manufactured after 1/1/2000. This limited warranty is not retroactive to any installations prior to 10/1/2001 or on product produced prior to 2000.

THE LIMITED WARRANTY AND LIABILITY SET FORTH HEREIN ARE IN LIEU OF ALL OTHER WARRANTIES AND LIABILITIES, WHETHER IN CONTRACT OR IN NEGLIGENCE, EXPRESS OR IMPLIED, IN LAW OR IN FACT, INCLUDING IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR PARTICULAR USE, AND IN NO EVENT SHALL WARRANTOR BE LIABLE FOR ANY INCIDENTAL OR CONSEQUENTIAL DAMAGES.

Some states do not allow limitations on how long an implied warranty lasts or do not allow the exclusion or limitation of incidental or consequential damages, so the above limitation may not apply to you. This limited warranty gives you specific legal rights, and you may also have other rights which vary from state to state.

Parts will be provided by our factory organization or an authorized service organization in your area listed in the yellow pages. If you wish further help or information concerning this warranty, contact:

American Standard Inc.
Troup Highway
Tyler, TX 75711-9010
Attention: Manager, After Sales Support

CUSTOMER ASSISTANCE

If, after reading this guide, you have any questions concerning the operation of your thermostat, please call the Thermostat Customer Assistance Helpline at 1-800-500-2041.

For service, contact your local heating and cooling contractor.

Pub. No. 12-5026-01

® U.S. Registered Trademark
69-1609 4-02 G.H. Printed in Mexico

*American
Standard*

American Standard Inc.
Troup Highway
Tyler, TX 75711-9010